

2024 drinking water quality report

CITY OF GLEN COVE WATER DEPARTMENT
PUBLIC WATER SUPPLY IDENTIFICATION NO. 2902826

ANNUAL WATER SUPPLY REPORT

MAY 2025

The City continues its commitment to provide our residents with drinking water that meets or exceeds quality standards while taking the necessary steps to improve our water supply system infrastructure.

Pamela D. Panzenbeck
Mayor

SOURCE OF OUR WATER


The source of water for the City is groundwater pumped from five (5) wells located throughout the community that are drilled into the aquifers beneath Long Island, as shown on the adjacent figure. Generally, the water quality of the aquifers is good to excellent.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radiological contaminants.

In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The population served by the City of Glen Cove during 2024 was 28,500. The total amount of water pumped by the City in 2024 was 1.317 billion gallons, of which approximately 87 percent was billed directly to consumers.

The remaining un-metered water is from uses such as municipal and public school facilities, fire fighting, hydrant flushing, main breaks and undetected service line and water main leaks.



THE LONG ISLAND AQUIFER SYSTEM

WATER TREATMENT

The Water Department treats the water supply before it enters the distribution system. A small amount of chlorine is added to assure the water maintains its bacteria-free quality. Our water is also treated with sodium hydroxide to increase its pH to reduce its corrosivity before it enters the distribution system. This treatment reduces the leaching of copper and lead from household plumbing. Source water from the Kelly Street, Seaman Road well and two (2) wells at Duck Pond Road are treated by air stripping to remove various volatile organic chemicals. Source water from the one (1) Duck Pond Road well is treated by granular activated carbon filters to remove various organic chemicals and pesticides. All treatment is approved by and in strict accordance with Nassau County Department of Health standards.

INFORMATION FOR NON-ENGLISH SPEAKING RESIDENTS

Spanish

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

CONTACTS FOR ADDITIONAL INFORMATION

If you have any questions about this report or concerning your water utility, please contact Michael Colangelo at the Water Department at (516) 676-2238 or the Nassau County Department of Health at (516) 227-9692. We want our valued customers to be informed about our water system. If you want to learn more, you can attend any of our regularly scheduled City Council meetings. They are normally held on the second and fourth Tuesday of each month at 7:30 p.m. at City Hall, unless otherwise posted.

The City of Glen Cove routinely monitors for different parameters and contaminants in your drinking water as required by Federal and State laws. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk. For more information on contamination and potential health risks, please contact the USEPA Safe Drinking Water Hotline at 1-800-426-4791.

During 2023, the City Water Department collected 30 samples for lead and copper. The next round of samples will occur in 2026. If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The City of Glen Cove is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. If you are caring for an infant you should ask advice from your health care provider.

WATER CONSERVATION MEASURES

The underground water system of Long Island has more than enough water for present water demands. However, saving water will ensure that our future generations will always have a safe and abundant water supply.

In 2024, the City of Glen Cove continued to implement a water conservation program in order to minimize any unnecessary water use. The pumpage for 2024 was approximately 1.4% less than the pumpage for 2023.

Water supply management has long been a practice in Glen Cove. Over the last 20 years, the city has initiated numerous programs geared to reducing water usage. Obviously, continued water conservation efforts will be required to maintain ample supplies.

Some of the major water conservation measures implemented by the City are:

Water Conservation Ordinances – local ordinances have long been in effect to restrict non-potable water use during periods of peak demand, such as Summer periods and fire emergencies. In 1987, the City, in an effort to promote conservation, amended its municipal ordinances and adopted stricter regulations related to:

- Water sprinkling (odd/even) hours are 5:00 a.m. to 9:00 a.m. and then again from 4:00 p.m. to midnight. There is NO watering permitted on the 31st of any month. Sprinkler systems must be equipped with a backflow device and rain sensor.

SOURCE WATER ASSESSMENT

The NYSDOH, with assistance from the local health department and the consulting firm CDM Smith, has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how rapidly contaminants can move through the subsurface to the wells. The susceptibility of a water supply well to contamination is dependent upon both the presence of potential sources of contamination within the well's contributing area and the likelihood that the contaminant can travel through the environment to reach the well. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See Section entitled "Water Quality" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

Drinking water is derived from 6 wells. The source water assessment has rated most of the wells as having a very high susceptibility to industrial solvents, all of the wells as having a high susceptibility to nitrates, and one well as having a medium high susceptibility to microbial contamination. The very high susceptibility to industrial solvents is due primarily to point sources of contamination related to transportation routes and commercial/industrial facilities and related activities in the assessment area. The high susceptibility to nitrate contamination is attributable to unsewered residential land use and related practices in the assessment area, such as fertilizing lawns. Therefore, continued vigilance in compliance with water quality protection and pollution prevention programs as well as continued monitoring and enforcement will help to continue to protect groundwater quality.

A copy of the assessment, including a map of the assessment area, can be obtained by contacting the City Water Dept.

The City of Glen Cove Water Department conducts over 5,000 water quality tests throughout the year, testing for over 135 different contaminants which have been undetected in our water supply including:

1,1,1,2-Tetrachloroethane	Aldicarb sulfone	Dieldrin	Oxamyl
1,1,1-Trichloroethane	Aldicarb sulfoxide	Dinoseb	o-Xylene
1,1,2,2-Tetrachloroethane	Aldrin	Diquat	PCB Screen
1,1,2-Trichloroethane	Antimony	E.coli	Pentachlorophenol
1,1,2-Trichlorotrifluoroethane	Apparent Color	Endothall	Perchlorate
1,1-Dichloroethane	Arsenic	Endrin	PFEESA
1,1-Dichloroethene	Atrazine	Ethylbenzene	PFMPA
1,1-Dichloropropene	Benzene	Fluoride	PFMBA
1,2,3-Trichlorobenzene	Benzo(a)pyrene	gamma-BHC (Lindane)	PFDA
1,2,3-Trichloropropane	Beryllium	Glyphosate	PFDOA
1,2,4-Trichlorobenzene	bis(2-Ethylhexyl)adipate	Haloacetic Acids (Total)	PFHpS
1,2,4-Trimethylbenzene	bis(2-Ethylhexyl)phthalate	Heptachlor	PFPeS
1,2-Dibromo-3-chloropropane	Bromobenzene	Heptachlor epoxide	PFUnA
1,2-Dibromoethane (EDB)	Bromochloromethane	Hexachloro-1,3-butadiene	Picloram
1,2-Dichlorobenzene	Bromomethane	Hexachlorobenzene	p-Isopropyltoluene
1,2-Dichloroethane	Butachlor	Hexachlorocyclopentadiene	Propachlor
1,2-Dichloropropane	Cadmium	Isopropylbenzene (Cumene)	sec-Butylbenzene
1,3,5-Trimethylbenzene	Carbaryl	Lead	Silver
1,3-Dichlorobenzene	Carbofuran	m&p-Xylene	Simazine
1,3-Dichloropropane	Carbon tetrachloride	Manganese	Styrene
1,4-Dichlorobenzene	Chlordane (Technical)	MBAS, Calculated as LAS	tert-Butylbenzene
11Cl-PF30UdS	Chlorobenzene	Mercury	Tetrachloroethene
8:2FTS	Chlorodifluoromethane	Methomyl	Thallium
4:2FTS	Chloroethane	Methoxychlor	Toluene
2,2-Dichloropropane	Chloromethane	Methylene Chloride	Total Coliforms
HFPO-DA	Chromium	Methyl-tert-butyl ether	Toxaphene
2,4,5-TP (Silvex)	cis-1,2-Dichloroethene	Metolachlor	trans-1,2-Dichloroethene
2,4-D	cis-1,3-Dichloropropene	Metribuzin	trans-1,3-Dichloropropene
2-Chlorotoluene	Cyanide, Free	Monobromoacetic Acid	Trichloroacetic Acid
3-Hydroxycarbofuran	Dalapon	Monochloroacetic Acid	Trichloroethene
ADONA	Dibromoacetic Acid	n-Butylbenzene	Trichlorofluoromethane
4-Chlorotoluene	Dibromomethane	Nitrite as N	Vinyl chloride
9Cl-PF30NS	Dicamba	Nitrogen, Ammonia	Chloroform
Alachlor	Dichloroacetic Acid	NFDHA	
Aldicarb	Dichlorodifluoromethane	n-Propylbenzene	
Dibromochloromethane	Bromodichloromethane	Bromoform	

- Car washing – only self closing shut off valved hose permitted for use.
- Water saving plumbing fittings and fixtures are required on all new residential and commercial construction and in certain alterations and additions to existing construction.

2024 DRINKING WATER QUALITY REPORT - TABLE OF DETECTED PARAMETERS

Contaminants	Violation (Yes/No)	Date of Sample	Level Detected (Maximum Range)	Unit Measurement	MCLG	Regulatory Limit (MCL or AL)	Likely Source of Contaminant
Lead & Copper Rule							
Copper	No	June/July/ August 2023	0.021 - 0.55 0.41 ⁽¹⁾	mg/l	1.3	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	No	June/July/ August 2023	ND - 14.0 3.9 ⁽¹⁾	ug/l	0	AL = 15	
Inorganic Contaminants							
Barium	No	05/08/24	0.02 - 0.03	mg/l	n/a	MCL = 2	Naturally occurring
Sodium	No	05/08/24	13.3 - 27.0	mg/l	n/a	No MCL ⁽²⁾	
Zinc	No	05/08/24	ND - 0.1	ug/l	n/a	MCL = 5000	
Nitrate	No	08/08/24	2.6 - 6.0	mg/l	n/a	MCL = 10	
Nitrate-Nitrite	No	08/08/24	2.6 - 6.0	mg/l	n/a	MCL = 10	
Iron	No	07/09/24	ND - 0.04	mg/l	n/a	MCL = 0.3	
Magnesium	No	05/08/24	6.3 - 9.8	mg/l	n/a	No MCL	
Chloride	No	02/07/24	ND - 37.9	mg/l	n/a	MCL = 250	
Calcium	No	05/08/24	15.5 - 23.4	mg/l	n/a	No MCL	
Nickel	No	02/15/24	ND - 0.0023	mg/l	n/a	No MCL	
Sulfate	No	07/19/24	19.8 - 31.9	mg/l	n/a	MCL = 250	
Selenium	No	07/19/24	ND - 2.4	ug/l	50	MCL = 50	Discharge from petroleum
Copper	No	05/08/24	ND - 0.0042	mg/l	1.3	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits
Disinfection By-Products							
Total Trihalomethanes	No	10/04/24	ND - 1.1	ug/l	n/a	MCL = 80	Disinfection By-Products
Radionuclides							
Gross Alpha	No	01/04/24	0.14 - 3.54	pCi/L	n/a	MCL = 15	Naturally occurring
Gross Beta	No	01/04/24	1.31 - 3.08	pCi/L	n/a	MCL = 50	
Radium 226 & 228 Combined	No	01/06/24	1.06 - 2.23	pCi/L	n/a	MCL = 5 ⁽⁴⁾	
Uranium	No	01/04/24	0.07 - 3.54	ug/l	n/a	MCL = 30	
Synthetic Organic Contaminants							
1,4-Dioxane	No	05/08/24	0.04 - 0.13	ug/l	n/a	MCL = 1.0 ⁽⁵⁾	Industrial discharge ⁽⁶⁾
Perfluorooctanesulfonic Acid (PFOS)	No	08/02/24	ND - 2.45	ng/l	n/a	MCL = 10.0 ⁽⁷⁾	Industrial discharge ⁽⁸⁾
Perfluorooctanoic Acid (PFOA)	No	08/02/24	ND - 7.04	ng/l	n/a	MCL = 10.0 ⁽⁷⁾	
Unregulated Contaminants							
Perfluorobutanoic Acid (PFBA)	No	08/02/24	ND - 4.55	ng/l	n/a	MCL = 50,000	Industrial discharge ⁽⁸⁾
Perfluorobutanesulfonic Acid (PFBS)	No	08/02/24	ND - 2.12	ng/l	n/a	MCL = 50,000	
Perfluoroheptanoic Acid (PFHpA)	No	08/02/24	ND - 4.52	ng/l	n/a	MCL = 50,000	
Perfluorohexanesulfonic Acid (PFHxS)	No	08/02/24	ND - 6.32	ng/l	n/a	MCL = 50,000	Commerical industrial applications
Perfluorohexanoic Acid (PFHxA)	No	08/02/24	ND - 6.85	ng/l	n/a	MCL = 50,000	
Perfluorononanoic Acid (PFNA)	No	08/02/24	ND - 4.75	ng/l	n/a	MCL = 50,000	
Perfluoropentanoic Acid (PFPeA)	No	08/02/24	ND - 10.2	ng/l	n/a	MCL = 50,000	
6:2FTS	No	02/07/24	ND - 4.72	ng/l	n/a	MCL = 50,000	

2024 DRINKING WATER QUALITY REPORT - TABLE OF DETECTED PARAMETERS (cont'd.)

Contaminants	Violation (Yes/No)	Date of Sample	Level Detected (Maximum Range)	Unit Measurement	MCLG	Regulatory Limit (MCL or AL)	Likely Source of Contaminant
Disinfectants							
Chlorine Residual	No	Continuous	0.4 - 0.9	mg/l	n/a	MRDL = 4.0	Measure of disinfectant
Physical Characteristics							
pH	No	Continuous	5.3 - 7.6	pH Units	n/a	7.5 - 8.5	Measure of water acidity or alkalinity
Total Hardness	No	05/08/24	64.80 - 99.0	mg/l	n/a	No MCL	Naturally occurring
Calcium Hardness	No	05/08/24	38.7 - 58.4	mg/l	n/a	No MCL	
Total Alkalinity	No	05/08/24	27.60 - 35.60	mg/l	n/a	No MCL	
Total Dissolved Solids	No	05/08/24	136.0 - 187.0	mg/l	n/a	No MCL	
Turbidity	No	07/19/24	ND - 1.9	NTU	n/a	MCL = 5	

Definitions:

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfection Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Health Advisory (HA) - An estimate of acceptable drinking water levels for a chemical substance based on health effects information; a health advisory is not a legally enforceable Federal standard, but serves as technical guidance to assist Federal, State and local officials.

Milligrams per liter (mg/l) - Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Nanograms per liter (ng/l) - Corresponds to one part of liquid in one trillion parts of liquid (parts per trillion - ppt).

Micrograms per liter (ug/l) - Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nephelometric (NTU) - signifies that the instrument is measuring scattered light from the sample at 90-degree angle from the incident light.

Non-Detects (ND) - Laboratory analysis indicates that the constituent is not present.

pCi/L - pico Curies per Liter is a measure of radioactivity in water.

⁽¹⁾ - During 2023, we collected and analyzed 30 samples for lead and copper. The action levels for lead had 1 sample that exceeded the MCL at 1 site. The action levels for copper was not exceeded at any site tested. The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system. In our sampling program, the 90th percentile value is the 4th highest result.

⁽²⁾ - If iron and manganese are present, the total concentration of both should not exceed 500 ug/l. Higher levels may be allowed by the State when justified by the supplier of water.

⁽³⁾ - Perchlorate is an unregulated contaminant. However, the State Health Dept. has established an action level of 18 ug/l.

⁽⁴⁾ - MCL is for combined Radium 226 and Radium 228.

⁽⁵⁾ - 1,4-Dioxane -The New York State (NYS) has established an MCL for 1,4 dioxane is 1.0 part per billion(ppb) effective August 26, 2020.

⁽⁶⁾ - It is used as a solvent for cellulose formulations, resins, oils, waxes and other organic substances. It is also used in wood pulping, textile processing, degreasing, in lacquers, paints, varnishes, and stains; and in paint and varnish removers.

⁽⁷⁾ - The US Environmental Protection Agency (EPA) has established a life time health advisory level (HAL) of 70 parts per trillion (ppt) for PFOA and PFOS combined. The New York State (NYS) established a maximum contaminant level (MCL) at 10 ppt for PFOA and 10 ppt for PFOS effective August 2020.

⁽⁸⁾ - PFOA has been used to make carpets, leathers, textiles, fabrics for furniture, paper packaging, and other materials that are resistant to water, greasing, or stains. It is also used in firefighting foams at airfields. Many of these uses have been phased out by its primary U.S. manufacturer; however, there are still some ongoing uses.

City of Glen Cove Water Department
9 Glen Street
Glen Cove, New York 11542-2798
(516) 676-2238

Bulk Rate
Carrier Presort
U.S. Postage
PAID
Glen Cove, NY
Permit No. 56

POSTAL CUSTOMER
GLEN COVE NY 11542

WATER QUALITY

In accordance with State regulations, the City of Glen Cove routinely monitors your drinking water for numerous parameters. We test your drinking water for coliform bacteria, turbidity, inorganic contaminants, lead and copper, nitrate, volatile organic contaminants, total trihalomethanes, synthetic organic contaminants and radiological contaminants. Over 135 separate parameters are tested for in each of our wells numerous times per year. Over 5,000 tests are taken each year from the distribution system and supply wells. The table presented on page 3 depicts which parameters or contaminants were detected in your drinking water. It should be noted that many of these parameters are naturally found in all Long Island drinking water and do not pose any adverse health affects.

WATER SYSTEM IMPROVEMENTS

The City of Glen Cove is committed to providing Glen Cove residents with the highest quality water and to improve the overall efficiency of the system. With this in mind, the Department of Public Works had undertaken an internal audit of all water department facilities, mechanical systems and delivery infrastructure system improvements are made as necessary. The City is in the process of constructing an air stripping treatment facility at Duck Pond Road well site for the removal of the contaminant Freon and the rehabilitation of Nancy Court.

COST OF WATER

Our residential rate structure for each 3 month period is as follows: \$2.71 per 1,000 for the first 45,000 gallons, \$3.06 per 1,000 gallons for the next 45,000 gallons, and \$3.39 per 1,000 gallons for usage over 90,000 gallons.

INFORMATION ON LEAD SERVICE
LINE INVENTORY

During 2023, the City collected 34 samples from June through August for lead and copper.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The City of Glen Cove is responsible for providing high quality drinking water but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family’s risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact the City of Glen Cove, Michael Colangelo at (516) 676-2238. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible on our website at <https://glencoveny.gov/wp-content/uploads/2022/02/Lead-Service-Line-Replacement-Program-Glen-Cove.pdf>, or at the City’s office during normal business hours or it can be emailed directly upon request.

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 2S-A						Well 30			Well 31			Well 30/31		
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
INORGANICS																	
Antimony	6	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Apparent Color	15	units	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Arsenic	10	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Barium	2	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	0.022	0.020	2	0.027	0.026	1	0.026	0.026
Beryllium	4	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Ca Hardness as CaCO3 (SM 2340B	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	39.20	38.95	2	41.90	39.95	1	38.70	38.70
Cadmium	5	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Chloride	250	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	37.90	32.40	2	24.40	23.00	1	22.60	22.60
Chromium	100	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Copper	1.3	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	0.01	0.01	2	0.01	0.01	1	0.00	0.00
Fluoride	2.2	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Iron	0.3	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	0.09	0.05	2	0.04	0.02	1	ND	ND
Lead	15	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Manganese	0.3	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
MBAS, Calculated as LAS	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Mercury	2	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Nickel	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Nitrate as N	10	mg/L	1	3.00	3.00	n/a	n/a	n/a	2	3.90	3.80	4	3.80	3.60	1	3.30	3.30
Nitrate-Nitrite (as N)	10	mg/L	1	3.00	3.00	n/a	n/a	n/a	2	3.90	3.80	4	3.80	3.60	1	3.30	3.30
Nitrite as N	1	mg/L	1	ND	ND	n/a	n/a	n/a	2	ND	ND	4	ND	ND	1	ND	ND
Nitrogen, Ammonia	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Odor @ 60 Degrees C	3		n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Selenium	50	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Silver	0.1	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Sodium	270	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	18.10	17.85	2	14.60	14.00	1	13.30	13.30
Sulfate	250	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	19.80	18.85	2	28.00	26.50	1	24.70	24.70
Thallium	2	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Zinc	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Calcium	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	15.70	15.60	2	16.80	16.00	1	15.50	15.50
Cyanide, Free	200	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND	1	ND	ND
Magnesium	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	6.70	6.50	2	7.00	6.70	1	7.40	7.40
Perchlorate	18	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
VOLATILE ORGANIC CONTAMINANTS																	
1,1,1-Trichloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1,2-Trichloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1,2-Trichlorotrifluoroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1-Dichloroethene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2,4-Trichlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2-Dichlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2-Dichloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2-Dichloropropane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,4-Dichlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Benzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Carbon tetrachloride	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Chlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
cis-1,2-Dichloroethene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Ethylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Hexachloro-1,3-butadiene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
m&p-Xylene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Methyl-tert-butyl ether	10	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
o-Xylene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Styrene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Tetrachloroethene	5	ug/L	1	1.20	1.20	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Toluene	5	ug/L	1	ND	ND	3	ND	ND	32	1.40	0.04	3	ND	ND	39	ND	ND
trans-1,2-Dichloroethene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Trichloroethene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Vinyl chloride	2	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
SYNTHETIC ORGANIC CONTAMINANTS																	
1,4-Dioxane (p-Dioxane)	1	ug/L	1	0.04	0.04	n/a	n/a	n/a	4	0.12	0.06	3	0.07	0.06	1	0.05	0.05
Perfluorooctanoic Acid (PFOA)	10	ng/l	1	2.89	2.89	n/a	n/a	n/a	4	5.72	3.49	3	7.09	6.51	4	7.04	4.69
Perfluorooctanesulfonic Acid (PFOS)	10	ng/l	1	ND	ND	n/a	n/a	n/a	4	1.86	0.47	3	2.78	2.33	4	2.45	1.04

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 2S-A						Well 30			Well 31			Well 30/31		
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
2,4,5-TP (Silvex)	10	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
2,4-D	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Dalapon	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Dicamba	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Dinoseb	7	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Pentachlorophenol	1	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Picloram	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Atrazine	3	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Metolachlor	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Metribuzin	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Propachlor	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Simazine	4	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Hexachlorocyclopentadiene	5	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
3-Hydroxycarbofuran	50	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Aldicarb	3	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Aldicarb sulfone	2	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Aldicarb sulfoxide	4	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Carbofuran	40	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Methomyl	50	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Oxamyl	200	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
Glyphosate	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Endothall	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Diquat	20	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Alachlor	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Chlordane (Technical)	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Endrin	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
gamma-BHC (Lindane)	0.2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Heptachlor	400	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Heptachlor epoxide	200	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Benzo(a)pyrene	200	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
bis(2-Ethylhexyl)adipate	400	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
bis(2-Ethylhexyl)phthalate	6	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Hexachlorobenzene	1	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Methoxychlor	40	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
PCB Screen	0.5	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Toxaphene	3	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
1,2-Dibromo-3-chloropropane	200	ug/L	2	ND	ND	1	ND	ND	5	ND	ND	4	ND	ND	5	ND	ND
1,2-Dibromoethane (EDB)	50	ug/L	2	ND	ND	1	ND	ND	5	ND	ND	4	ND	ND	5	ND	ND
UCMR5																	
Perfluorobutanesulfonic Acid (PFBS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	2.16	1.34	4	2.12	0.53
Perfluoroheptanoic Acid (PFHpA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	2.33	1.11	3	4.36	2.47	4	4.52	1.72
Perfluorohexanesulfonic Acid (PFHxS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	2.41	1.10	3	7.30	3.72	4	6.32	2.64
Perfluorononanoic Acid (PFNA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	6.00	3.90	4	4.75	1.77
4,8-Dioxa-3h-Perfluorononanoic Acid (ADONA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluoro(2-Ethoxyethane)Sulfonic Acid (PFESA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Nonafluoro-3,6-Dioxaheptanoic Acid (NFDHA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluorobutanoic Acid (PFBA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	2.80	1.85	3	4.52	3.58	4	4.55	3.08
Perfluorodecanoic Acid (PFDA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluorododecanoic Acid (PFDoA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluoroheptanesulfonic Acid (PFHpS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluorohexanoic Acid (PFHxA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	3.32	1.59	3	8.12	5.08	4	6.85	3.85
Perfluoropentanesulfonic Acid (PFPeS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluoropentanoic Acid (PFPeA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	4.25	2.39	3	9.58	6.42	4	10.20	5.18
Perfluoroundecanoic Acid (PFUnA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluoro-3-Methoxypropanoic Acid (PFMPA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
Perfluoro-4-Methoxybutanoic Acid (PFMBA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorohexanesulfonic Acid (4:2FTS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	4.72	1.18
9-Chlorohexadecafluoro-3-Oxanone-1-Sulfonic Acid (9Cl-PF3ONS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
11-Chloroeicosafluoro-3-Oxaundecane-1-Sulfonic Acid (11Cl-PF3OUdS)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND
2,3,3,3-Tetrafluoro-2-[1,1,2,2,3,3,3-Heptafluoropropoxy]-Propanoic Acid (HFPO-DA)	50,000	ng/l	1	ND	ND	n/a	n/a	n/a	4	ND	ND	3	ND	ND	4	ND	ND

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

			Well 2S-A						Well 30			Well 31			Well 30/31		
ANALYTES	M.C.L.	Units	Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
OTHER PRINCIPAL ORGANIC CONTAMINANTS																	
1,1,1,2-Tetrachloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1,2,2-Tetrachloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1-Dichloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,1-Dichloropropene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2,3-Trichlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2,3-Trichloropropane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,2,4-Trimethylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,3,5-Trimethylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,3-Dichlorobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
1,3-Dichloropropane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
2,2-Dichloropropane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
2-Chlorotoluene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
4-Chlorotoluene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Bromobenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Bromochloromethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Bromomethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Chlorodifluoromethane	5	ug/L	1	ND	ND	3	ND	ND	32	1.30	0.52	3	3.60	1.20	39	ND	ND
Chloroethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Chloromethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
cis-1,3-Dichloropropene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Dibromomethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Dichlorodifluoromethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Isopropylbenzene (Cumene)	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Methylene Chloride	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
n-Butylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
n-Propylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
p-Isopropyltoluene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
sec-Butylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
tert-Butylbenzene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
trans-1,3-Dichloropropene	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Trichlorofluoromethane	5	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Aldrin	5	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Dieldrin	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
UNSPECIFIED ORGANIC CONTAMINANTS																	
Butachlor	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Carbaryl	50	ug/L	1	ND	ND	1	ND	ND	3	ND	ND	1	ND	ND	1	ND	ND
DISINFECTION BYPRODUCTS																	
Bromodichloromethane	50	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Bromoform	50	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Chloroform	50	ug/L	1	ND	ND	3	ND	ND	32	2.40	0.11	3	ND	ND	39	ND	ND
Dibromochloromethane	50	ug/L	1	ND	ND	3	ND	ND	32	ND	ND	3	ND	ND	39	ND	ND
Total Trihalomethanes (Calc.)	80	ug/L	1	ND	ND	3	ND	ND	32	2.40	0.11	3	ND	ND	39	ND	ND
OTHER																	
Alkalinity, Total as CaCO3	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	31.00	30.20	2	31.00	29.90	1	31.30	31.30
E.coli	n/a		n/a	n/a	n/a	5	ND	ND	45	1.00	0.02	20	ND	ND	20	ND	ND
Field pH	n/a	Std. Units	n/a	n/a	n/a	n/a	n/a	n/a	2	8.40	7.90	2	8.30	7.45	1	8.40	8.40
Field Residual Chlorine	1	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	20	0.80	0.58
Field Temperature	n/a	deg C	n/a	n/a	n/a	n/a	n/a	n/a	2	13.80	13.55	2	16.30	14.15	1	10.90	10.90
LAS Molecular Weight, g/mol	n/a		n/a	n/a	n/a	n/a	n/a	n/a	2	320.00	320.00	2	320.00	320.00	1	320.00	320.00
pH	n/a	Std. Units	n/a	n/a	n/a	n/a	n/a	n/a	2	6.00	5.80	2	6.00	5.65	1	7.60	7.60
Tot Hardness asCaCO3 (SM 2340B	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	66.90	65.85	2	70.80	67.50	1	69.10	69.10
Total Coliforms	n/a		n/a	n/a	n/a	5	ND	ND	45	1.00	0.38	20	ND	ND	20	ND	ND

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 2S-A						Well 30			Well 31			Well 30/31		
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
Turbidity	5	NTU	n/a	n/a	n/a	n/a	n/a	n/a	2	1.90	0.95	2	1.30	1.15	1	ND	ND
Corrosivity	n/a		n/a	n/a	n/a	n/a	n/a	n/a	2	-0.57	-1.07	2	-0.74	-1.50	1	-0.61	-0.61
Total Dissolved Solids	n/a	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	2	134.00	130.50	2	136.00	125.00	1	151.00	151.00
RADIOACTIVE CONTAMINANTS																	
Gross Alpha	15	pCi/L	1	-0.17	-0.17	n/a	n/a	n/a	1	3.03	3.03	1	2.03	2.03	1	2.46	2.46
Gross Beta	50	pCi/L	1	0.50	0.50	n/a	n/a	n/a	1	1.51	1.51	1	2.00	2.00	1	1.80	1.80
Radium-226	5	pCi/L	1	ND	ND	n/a	n/a	n/a	1	0.73	0.73	1	0.55	0.55	1	0.21	0.21
Radium-228	5	pCi/L	1	0.91	0.91	n/a	n/a	n/a	1	1.33	1.33	1	1.35	1.35	1	1.10	1.10
Propionic Acid	50	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
METALS																	
Chromium, Hexavalent	n/a	ug/L	2	0.41	0.41	2	0.17	0.09	2	0.39	0.37	2	ND	ND	n/a	n/a	n/a
DISINFECTION BYPRODUCTS																	
Bromodichloromethane	50	ug/L	8	5.10	0.64	8	ND	ND	8	ND	ND	8	ND	ND	3	ND	ND
Bromoform	50	ug/L	8	1.30	0.26	8	ND	ND	8	ND	ND	8	ND	ND	3	ND	ND
Chloroform	50	ug/L	8	4.00	1.03	8	ND	ND	8	ND	ND	8	ND	ND	3	ND	ND
Dibromoacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Dibromochloromethane	50	ug/L	8	5.40	0.74	8	ND	ND	8	ND	ND	8	ND	ND	3	ND	ND
Dichloroacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Haloacetic Acids (Total)	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Monobromoacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Monochloroacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Total Trihalomethanes (Calc.)	80	ug/L	8	15.90	2.68	8	ND	ND	8	ND	ND	8	ND	ND	3	ND	ND
Trichloroacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Chlorate	n/a	ug/L	2	15.60	14.10	2	ND	ND	2	ND	ND	2	ND	ND	n/a	n/a	n/a
Bromochloroacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Bromodichloroacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Chlorodibromoacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
Tribromoacetic Acid	60	ug/L	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a	2	ND	ND	n/a	n/a	n/a
OTHER																	
E.coli	n/a		5	ND	ND	12	ND	ND	5	ND	ND	12	ND	ND	4	ND	ND
Field pH	n/a	Std. Units	1	5.70	5.70	n/a	n/a	n/a	1	5.40	5.40	n/a	n/a	n/a	1	5.90	5.90
Field Residual Chlorine	1	mg/L	3	ND	ND	6	ND	ND	3	ND	ND	6	ND	ND	4	ND	ND
Field Temperature	n/a	deg C	1	16.00	16.00	n/a	n/a	n/a	1	15.00	15.00	n/a	n/a	n/a	1	17.20	17.20
LAS Molecular Weight, g/mol	n/a		1	320.00	320.00	n/a	n/a	n/a	1	320.00	320.00	n/a	n/a	n/a	1	320.00	320.00
pH	n/a	Std. Units	1	5.50	5.50	1	4.60	4.60	1	4.50	4.50	n/a	n/a	n/a	1	5.70	5.70
Tot Hardness asCaCO3 (SM 2340B	n/a	mg/L	1	21.80	21.80	n/a	n/a	n/a	1	13.80	13.80	n/a	n/a	n/a	1	60.20	60.20
Total Coliforms	n/a		5	ND	ND	12	ND	ND	5	ND	ND	12	ND	ND	4	ND	ND
Cyanide	50	ug/L	1	ND	ND	n/a	n/a	n/a	1	ND	ND	n/a	n/a	n/a	1	ND	ND
Specific Conductance	n/a	umhos/cm	1	149.00	149.00	n/a	n/a	n/a	1	75.30	75.30	n/a	n/a	n/a	1	257.00	257.00

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 32						Well Nancy			Well Kelly					
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
INORGANICS																	
Antimony	6	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Apparent Color	15	units	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Arsenic	10	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Barium	2	mg/L	1	0.030	0.030	1	0.030	0.030	1	0.021	0.021	1	0.018	0.018	1	0.018	0.018
Beryllium	4	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Ca Hardness as CaCO3 (SM 2340B	n/a	mg/L	1	58.90	58.90	1	58.40	58.40	1	42.90	42.90	1	45.40	45.40	1	52.70	52.70
Cadmium	5	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Chloride	250	mg/L	1	52.40	52.40	1	ND	ND	1	29.90	29.90	1	21.60	21.60	1	23.50	23.50
Chromium	100	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Copper	1.3	mg/L	1	ND	ND	1	0.00	0.00	1	0.00	0.00	1	0.01	0.01	1	ND	ND
Fluoride	2.2	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Iron	0.3	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Lead	15	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Manganese	0.3	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
MBAS, Calculated as LAS	n/a	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Mercury	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Nickel	n/a	mg/L	1	ND	ND	1	0.00	0.00	1	0.00	0.00	1	ND	ND	1	ND	ND
Nitrate as N	10	mg/L	4	6.30	5.80	4	6.00	4.90	3	5.90	5.37	4	5.80	5.43	4	5.70	5.40
Nitrate-Nitrite (as N)	10	mg/L	4	6.30	5.80	4	6.00	4.90	3	5.90	5.37	4	5.80	5.43	4	5.70	5.40
Nitrite as N	1	mg/L	4	ND	ND	4	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Nitrogen, Ammonia	n/a	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Odor @ 60 Degrees C	3		1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	1.00	1.00
Selenium	50	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	2.00	2.00	1	2.40	2.40
Silver	0.1	mg/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Sodium	270	mg/L	1	27.20	27.20	1	27.00	27.00	1	17.00	17.00	1	11.90	11.90	1	14.30	14.30
Sulfate	250	mg/L	1	27.50	27.50	1	27.80	27.80	1	22.70	22.70	1	32.30	32.30	1	31.90	31.90
Thallium	2	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Zinc	n/a	mg/L	1	ND	ND	1	0.100	0.100	1	0.032	0.032	1	ND	ND	1	ND	ND
Calcium	n/a	mg/L	1	23.60	23.60	1	23.40	23.40	1	17.20	17.20	1	18.20	18.20	1	21.10	21.10
Cyanide, Free	200	ug/L	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Magnesium	n/a	mg/L	1	10.00	10.00	1	9.80	9.80	1	6.60	6.60	1	7.30	7.30	1	8.40	8.40
Perchlorate	18	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	2	ND	ND	2	ND	ND
VOLATILE ORGANIC CONTAMINANTS																	
1,1,1-Trichloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1,2-Trichloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1,2-Trichlorotrifluoroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1-Dichloroethene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2,4-Trichlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2-Dichlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2-Dichloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2-Dichloropropane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,4-Dichlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Benzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Carbon tetrachloride	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Chlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
cis-1,2-Dichloroethene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Ethylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Hexachloro-1,3-butadiene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
m&p-Xylene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Methyl-tert-butyl ether	10	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
o-Xylene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Styrene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Tetrachloroethene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Toluene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
trans-1,2-Dichloroethene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Trichloroethene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Vinyl chloride	2	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
SYNTHETIC ORGANIC CONTAMINANTS																	
1,4-Dioxane (p-Dioxane)	1	ug/L	4	0.13	0.11	1	0.07	0.07	3	0.09	0.09	4	0.08	0.06	n/a	n/a	n/a
Perfluorooctanoic Acid (PFOA)	10	ng/l	12	11.90	9.67	12	2.09	0.48	3	6.21	5.52	4	3.25	2.64	4	3.27	2.71
Perfluorooctanesulfonic Acid (PFOS)	10	ng/l	12	3.03	2.61	12	ND	ND	3	2.15	2.03	4	ND	ND	4	ND	ND

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 32						Well Nancy			Well Kelly					
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
2,4,5-TP (Silvex)	10	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
2,4-D	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Dalapon	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Dicamba	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Dinoseb	7	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Pentachlorophenol	1	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Picloram	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Atrazine	3	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Metolachlor	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	1	ND	ND	1	ND	ND
Metribuzin	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Propachlor	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Simazine	4	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Hexachlorocyclopentadiene	5	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
3-Hydroxycarbofuran	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Aldicarb	3	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Aldicarb sulfone	2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Aldicarb sulfoxide	4	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Carbofuran	40	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Methomyl	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Oxamyl	200	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Glyphosate	50	ug/L	4	ND	3.4	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Endothall	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Diquat	20	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Alachlor	2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Chlordane (Technical)	2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Endrin	2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
gamma-BHC (Lindane)	0.2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Heptachlor	400	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Heptachlor epoxide	200	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Benzo(a)pyrene	200	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
bis(2-Ethylhexyl)adipate	400	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
bis(2-Ethylhexyl)phthalate	6	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Hexachlorobenzene	1	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Methoxychlor	40	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	3	ND	ND	3	ND	ND
PCB Screen	0.5	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Toxaphene	3	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
1,2-Dibromo-3-chloropropane	200	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
1,2-Dibromoethane (EDB)	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
UCMR5																	
Perfluorobutanesulfonic Acid (PFBS)	50,000	ng/l	12	2.01	1.24	12	ND	ND	3	1.88	1.21	4	ND	ND	4	ND	ND
Perfluoroheptanoic Acid (PFHpA)	50,000	ng/l	12	4.03	3.43	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluorohexanesulfonic Acid (PFHxS)	50,000	ng/l	12	5.11	2.97	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluorononanoic Acid (PFNA)	50,000	ng/l	12	4.31	1.04	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
4,8-Dioxa-3h-Perfluorononanoic Acid (ADONA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluoro(2-Ethoxyethane)Sulfonic Acid (PFESA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Nonafluoro-3,6-Dioxaheptanoic Acid (NFDHA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluorobutanoic Acid (PFBA)	50,000	ng/l	12	5.12	4.16	12	4.16	2.00	3	2.47	2.39	4	ND	ND	4	ND	ND
Perfluorodecanoic Acid (PFDA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluorododecanoic Acid (PFDoA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluoroheptanesulfonic Acid (PFHpS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluorohexanoic Acid (PFHxA)	50,000	ng/l	12	6.80	4.89	12	1.95	0.47	3	2.96	2.78	4	1.78	0.45	4	1.88	0.47
Perfluoropentanesulfonic Acid (PFPeS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluoropentanoic Acid (PFPeA)	50,000	ng/l	12	8.84	5.77	12	3.22	1.41	3	2.81	2.71	4	ND	ND	4	ND	ND
Perfluoroundecanoic Acid (PFUnA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluoro-3-Methoxypropanoic Acid (PFMPA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
Perfluoro-4-Methoxybutanoic Acid (PFMBA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorohexanesulfonic Acid (4:2FTS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorooctanesulfonic Acid (6:2FTS)	50,000	ng/l	12	1.70	0.14	12	3.02	0.25	3	ND	ND	4	ND	ND	4	ND	ND
9-Chlorohexadecafluoro-3-Oxanone-1-Sulfonic Acid (9Cl-PF3ONS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
1H,1H,2H,2H-Perfluorodecanesulfonic Acid (8:2FTS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
11-Chloroeicosafluoro-3-Oxaundecane-1-Sulfonic Acid (11Cl-PF3OUdS)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND
2,3,3,3-Tetrafluoro-2-[1,1,2,2,3,3,3-Heptafluoropropoxy]-Propanoic Acid (HFPO-DA)	50,000	ng/l	12	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	4	ND	ND

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

			Well 32						Well Nancy			Well Kelly					
ANALYTES	M.C.L.	Units	Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
OTHER PRINCIPAL ORGANIC CONTAMINANTS																	
1,1,1,2-Tetrachloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1,2,2-Tetrachloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1-Dichloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,1-Dichloropropene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2,3-Trichlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2,3-Trichloropropane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,2,4-Trimethylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,3,5-Trimethylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,3-Dichlorobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
1,3-Dichloropropane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
2,2-Dichloropropane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
2-Chlorotoluene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
4-Chlorotoluene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Bromobenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Bromochloromethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Bromomethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Chlorodifluoromethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Chloroethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Chloromethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
cis-1,3-Dichloropropene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Dibromomethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Dichlorodifluoromethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Isopropylbenzene (Cumene)	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Methylene Chloride	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
n-Butylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
n-Propylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
p-Isopropyltoluene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
sec-Butylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
tert-Butylbenzene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
trans-1,3-Dichloropropene	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Trichlorofluoromethane	5	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Aldrin	5	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Dieldrin	2	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
UNSPECIFIED ORGANIC CONTAMINANTS																	
Butachlor	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
Carbaryl	50	ug/L	4	ND	ND	4	ND	ND	1	ND	ND	2	ND	ND	2	ND	ND
DISINFECTION BYPRODUCTS																	
Bromodichloromethane	50	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Bromoform	50	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Chloroform	50	ug/L	20	1.00	0.64	12	ND	ND	3	0.56	0.19	4	ND	ND	12	ND	ND
Dibromochloromethane	50	ug/L	20	ND	ND	12	ND	ND	3	ND	ND	4	ND	ND	12	ND	ND
Total Trihalomethanes (Calc.)	80	ug/L	20	1.00	0.64	12	ND	ND	3	0.56	0.19	4	ND	ND	12	ND	ND
OTHER																	
Alkalinity, Total as CaCO3	n/a	mg/L	1	36.40	36.40	1	35.60	35.60	1	32.80	32.80	1	26.90	26.90	1	27.60	27.60
E.coli	n/a		9	ND	ND	20	ND	ND	3	ND	ND	20	ND	ND	20	ND	ND
Field pH	n/a	Std. Units	1	7.60	7.60	1	7.90	7.90	1	7.60	7.60	1	7.90	7.90	1	8.05	8.05
Field Residual Chlorine	1	mg/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	15	0.70	0.63
Field Temperature	n/a	deg C	1	14.40	14.40	1	14.40	14.40	1	11.40	11.40	1	11.90	11.90	1	12.00	12.00
LAS Molecular Weight, g/mol	n/a		1	320.00	320.00	1	320.00	320.00	1	320.00	320.00	1	320.00	320.00	1	320.00	320.00
pH	n/a	Std. Units	1	6.20	6.20	1	6.10	6.10	1	5.40	5.40	1	6.30	6.30	1	7.10	7.10
Tot Hardness asCaCO3 (SM 2340B	n/a	mg/L	1	99.90	99.90	1	99.00	99.00	1	70.30	70.30	1	75.70	75.70	1	87.20	87.20
Total Coliforms	n/a		9	ND	ND	20	ND	ND	3	ND	ND	20	ND	ND	20	ND	ND

CITY OF GLEN COVE
SUPPLEMENTAL WATER QUALITY TABLE 2024

ANALYTES	M.C.L.	Units	Well 32						Well Nancy			Well Kelly					
			Raw Well			Treated Well			Raw Well			Raw Well			Treated Well		
			SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG	SAMPLE COUNT	MAX	AVG
Turbidity	5	NTU	1	ND	ND	1	ND	ND	1	1.10	1.10	1	1.60	1.60	1	1.90	1.90
Corrosivity	n/a		1	-1.10	-1.10	1	-0.81	-0.81	1	-1.34	-1.34	1	-1.09	-1.09	1	-0.87	-0.87
Total Dissolved Solids	n/a	mg/L	1	195.00	195.00	1	187.00	187.00	1	156.00	156.00	1	135.00	135.00	1	151.00	151.00
RADIOACTIVE CONTAMINANTS																	
Gross Alpha	15	pCi/L	1	2.86	2.86	1	1.50	1.50	1	0.14	0.14	1	2.43	2.43	1	3.54	3.54
Gross Beta	50	pCi/L	1	2.21	2.21	1	2.49	2.49	1	1.31	1.31	1	1.90	1.90	1	3.08	3.08
Radium-226	5	pCi/L	1	1.24	1.24	1	0.82	0.82	1	0.71	0.71	1	0.60	0.60	1	0.14	0.14
Radium-228	5	pCi/L	1	1.68	1.68	1	2.23	2.23	1	1.06	1.06	1	1.12	1.12	1	1.09	1.09
Propionic Acid	50	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
METALS																	
Chromium, Hexavalent	n/a	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
DISINFECTION BYPRODUCTS																	
Bromodichloromethane	50	ug/L	3	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND
Bromoform	50	ug/L	3	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND
Chloroform	50	ug/L	3	ND	ND	4	1.10	0.90	4	0.99	0.87	4	ND	ND	4	ND	ND
Dibromoacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Dibromochloromethane	50	ug/L	3	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND	4	ND	ND
Dichloroacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Haloacetic Acids (Total)	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Monobromoacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Monochloroacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Total Trihalomethanes (Calc.)	80	ug/L	3	ND	ND	4	1.10	0.90	4	0.99	0.87	4	ND	ND	4	ND	ND
Trichloroacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Chlorate	n/a	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Bromochloroacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Bromodichloroacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Chlorodibromoacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Tribromoacetic Acid	60	ug/L	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
OTHER																	
E.coli	n/a		29	ND	ND	5	ND	ND	12	ND	ND	5	ND	ND	12	ND	ND
Field pH	n/a	Std. Units	n/a	n/a	n/a	1	5.10	5.10	n/a	n/a	n/a	1	5.20	5.20	n/a	n/a	n/a
Field Residual Chlorine	1	mg/L	19	ND	ND	4	ND	ND	9	ND	ND	4	ND	ND	9	ND	ND
Field Temperature	n/a	deg C	n/a	n/a	n/a	1	14.80	14.80	n/a	n/a	n/a	1	15.60	15.60	n/a	n/a	n/a
LAS Molecular Weight, g/mol	n/a		n/a	n/a	n/a	1	320.00	320.00	n/a	n/a	n/a	1	320.00	320.00	n/a	n/a	n/a
pH	n/a	Std. Units	n/a	n/a	n/a	1	4.70	4.70	n/a	n/a	n/a	1	5.50	5.50	n/a	n/a	n/a
Tot Hardness asCaCO3 (SM 2340B	n/a	mg/L	n/a	n/a	n/a	1	8.30	8.30	n/a	n/a	n/a	1	3.20	3.20	n/a	n/a	n/a
Total Coliforms	n/a		29	ND	ND	5	ND	ND	12	ND	ND	5	ND	ND	12	ND	ND
Cyanide	50	ug/L	n/a	n/a	n/a	1	ND	ND	n/a	n/a	n/a	1	ND	ND	n/a	n/a	n/a
Specific Conductance	n/a	umhos/cm	n/a	n/a	n/a	1	48.10	48.10	n/a	n/a	n/a	1	27.80	27.80	n/a	n/a	n/a