

Annual Drinking Water Quality Report for 2023
Wilton Water & Sewer Authority
20 Traver Road, Gansevoort NY 12831
Public Water Supply ID#NY4500186

INTRODUCTION

To comply with State regulations, Wilton Water and Sewer Authority (WWSA) will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact: Mr. Mike Mooney Director of the Wilton Water and Sewer Authority, at (518) 581-8626. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled board meetings held on the 3rd Tuesday of every other month at 4:00 PM at the Wilton Town Hall, 22 Traver Road, Gansevoort, NY 12831.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The WWSA draws its water from "groundwater" sources. Groundwater or well water is stored below the surface of the earth in deep, porous rocks called "aquifers." Groundwater is purified naturally as it filters through layers of soil, clay, rock and sand. This process, known as "percolation" takes years to complete. As a result, groundwater requires less treatment than surface water. Our Mulberry well field consists of 11 wells ranging in depth from 26 feet to 202 feet with yields on the various wells from 26 to 93 gallons per minute (gpm). Our Fairway well field consists of 11 wells ranging in depth from 70 feet -75 feet with yields of 40 gpm- 60 gpm. At present the Fairway well field is not being used due to high iron content. Treatment of the raw water produced by the wells at the Mulberry and Fairways Treatment Plants consists of chlorination with sodium hypochlorite which is used for disinfection to protect against contamination from harmful bacteria and other organisms. We have a 330,000-gallon storage/contact tank where the chlorine is added providing the necessary time to achieve adequate disinfection. At the Mulberry plant we have a 6,000-gallon hydro tank from which water is pumped with our high lift pumps. We also have a 330,000-gallon storage tank providing water into the distribution system utilizing one 15 horsepower (hp) centrifugal pump and three 25 hp centrifugal pumps to maintain pressure in the distribution system. At the Fairway Plant water is pumped from a 275,000 gallon in-ground concrete storage/contact tank with high lift pumps into the distribution system. One 15 hp, 120 gpm pump and two 25 hp 250 gpm pumps to maintain distribution system pressure. Both facilities have gas driven generators in the event of power outage.

Our O'Brien Treatment Plant on Jones Road which came on-line in late 2007 consists of 5 wells. The water is disinfected with sodium hypochlorite and flows into 750,000-gallon tank before being pumped into the distribution system.

We have an interconnection with the Saratoga County Water Authority's main transmission line. We have been purchasing 300,000 gallons of water per day. The water source for the SCWA is the Hudson River. Water treatment consists of addition of coagulant, powder activated carbon and filtration through 0.1-micron membrane filters. Caustic soda is added for pH adjustment and phosphate is added for corrosion control. Sodium hypochlorite is added for disinfection and to maintain a residual through the transmission system. There is a one 1 million-gallon water storage tank (clearwell) at the water plant. This tank provides contact time for proper disinfection of water and provides storage for our pumping and transmission system. The water treatment plant has been in service since February of 2010. A new carbon filtration system utilizing granular activated carbon has been added to the treatment process to reduce the levels of disinfection byproducts.

WWSA also purchases water from the City of Saratoga Springs that serves the Exit 15 commercial corridor. The area served by the City of Saratoga Springs water supply is the Home Depot Plaza and Price Chopper Plaza on Route 50. The other areas in the Exit 15 commercial corridor are supplied by WWSA water supply. The City of Saratoga Springs operates a surface

water filtration plant utilizing water from Loughberry Lake and Bog Meadow Brook as their source waters. The treatment process consists of sodium permanganate, during the summer and early fall, to address taste and odor issues, injection of the raw water with polyaluminum chloride coagulant as it flows to 2 parallel rapid mix basins. After coagulant addition, the water undergoes flocculation. Each train consists of a 3-stage 88,000-gallon flocculation basin (coagulation/flocculation causes small particles to stick together when the water is mixed forming larger heavier particles). A 157,000-gallon basin containing tube settlers allows the newly formed larger particles to settle out naturally in tube settlers. The plant has 4 dual media filter. The filter bed consists of anthracite coal and sand which removes smaller particles by trapping them in the spaces between the sand grains. The water is then disinfected with ultraviolet light and sodium hypochlorite before it is pumped into the distribution system. Fluoride is also added for the prevention of tooth decay. The only fluoridated water in the Town of Wilton is the water purchased from the City of Saratoga Springs and only serves the Home Depot Plaza and Price Chopper Plaza on Route 50.

FACTS AND FIGURES

Our water system serves approximately 9,240 people through 3,690 service connections. The total amount of water produced in 2023 was 410,036,000 gallons. The daily average of water treated and pumped into the distribution system was 1,123,386 gallons per day. Our highest single day consumption was 2,290,000 gallons. The amount of water sold and delivered to customers was 392,672,080 gallons or 95.77%. The difference (4.23%) between the volume billed and the total volume produced is water used firefighting, flushing of the water distribution system, errors in water meters and water lost to leaks. In 2023, water customers were charged \$3.87 per 1,000 gallons of water. The average annual charge for water is \$201.24.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, your drinking water is tested for numerous contaminants. These contaminants include: inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, disinfection byproducts, radiological and synthetic organic compounds. In addition, we test 10 samples for coliform bacteria monthly. The table presented below (starting on page four) depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline 800-426-4791 or the New York State Department of Health Glens Falls district office at (518) 793-3893.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the tables on pages 4-6, our system had no MCL violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

"In 2023, we were required to collect and analyze drinking water samples for 23 unregulated contaminants and 2 regulated contaminants on samples from our finished water in May 2023. One contaminant that is currently unregulated was from the Mulberry WTP. The data is shown in the table on page 5. One contaminant that is currently unregulated was found in a sample from Saratoga County Water Authority. Lastly, 2 regulated and 6 unregulated contaminants were found in water from Saratoga Springs water supply. The list of Unregulated and Regulated Compounds can be found on the last page. You may obtain the monitoring results by calling the Wilton Water and Sewer Authority office at (518) 581-8626

The Saratoga County Water Authority (SCWA) has been doing Cryptosporidium and Giardia monitoring on their untreated raw water during 2018. We are required to furnish the necessary health effects information.

Information on Cryptosporidium

Cryptosporidium is a microbial pathogen found in surface water and groundwater under the influence of surface water. Although filtration removes Cryptosporidium, the most commonly used filtration methods cannot guarantee 100 percent removal. The Saratoga County Water Authority utilizes membrane filtration technology which removes these contaminants at higher rates than conventional water treatment technologies. During 2018, as part of our routine sampling, eight samples were collected of untreated Hudson River source water and analyzed for Cryptosporidium oocysts. Of these samples, no oocysts were detected. Therefore, our testing indicates there was no presence of Cryptosporidium in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Cryptosporidium may cause cryptosporidiosis, a gastrointestinal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome disease within a few weeks. However, immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their health care provider regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

Information on Giardia

Giardia is a microbial pathogen present in varying concentrations in many surface waters and groundwater under the influence of surface

water. Giardia is removed/inactivated through a combination of filtration and disinfection or by disinfection. During 2018, as part of our routine sampling, eight samples were collected of untreated Hudson River source water and analyzed for Giardia cysts. Of these samples, seven samples showed a total of seventy-nine cysts and one sample showed no cysts. Therefore, our testing indicates the presence of Giardia in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Giardia may cause giardiasis, an intestinal illness. The Saratoga County Water Authority utilizes membrane filtration technology which removes these contaminants at higher rates than conventional water treatment technologies. People exposed to Giardia may experience mild or severe diarrhea, or in some instances no symptoms at all. Fever is rarely present. Occasionally, some individuals will have chronic diarrhea over several weeks or a month, with significant weight loss. Giardiasis can be treated with anti-parasitic medication. Individuals with weakened immune systems should consult with their health care providers about what steps would best reduce their risks of becoming infected with Giardiasis. Individuals who think that they may have been exposed to Giardiasis should contact their health care providers immediately. The Giardia parasite is passed in the feces of an infected person or animal and may contaminate water or food. Person to person transmission may also occur in day care centers or other settings where hand washing practices are poor.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2023, the Wilton Water and Sewer Authority was in compliance with the operating, monitoring and reporting requirements. We also purchase water from Saratoga Springs City Water Department and the Saratoga County Water Authority. Both of these systems were also in compliance with applicable State drinking water operating, monitoring and reporting requirements..

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater>.

INFORMATION ON FLUORIDE ADDITION

Fluoride is added to water by the City of Saratoga Springs before it is delivered to us. The customers served by the Home Depot Plaza AKA Wilton Square 3035 Rt 50 and Price Chopper Market 32 3045 rt 50 are the only 2 properties that receive this fluoridated water. All other customers that get their water from the WWSA do not receive fluoridated water. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, The City of Saratoga Springs monitors fluoride levels daily to make sure fluoride is maintained at a target level of 0.7 mg/l. During 2023, monitoring showed daily fluoride levels for the City's two plants were within 0.3 mg/L of the target level as recommended by the Department of Health. None of the monitoring results showed fluoride at levels that approached the 2.2 mg/L MCL for fluoride.

INFORMATION ON LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Wilton Water Department is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Mr. Mike Mooney, Town of Wilton (518) 581-8626. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 gallons to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

Follow the water conservation measures implemented by the Wilton Water and Sewer Authority to conserve outside water use. For July, August and September odd numbered homes on odd days can use outside water from 7-9 AM and 7-9 PM while even numbered homes on even days can use outside water from 7-9 AM and 7-9 PM.

SYSTEM IMPROVEMENTS

The following capital improvements were made to the water system in 2023:

- ◆ 6,120 feet of new water main was installed on Edie Rd.

WATER SYSTEM SECURITY

We ask that our customers be diligent and report any unusual activity they may see involving the water system such as tampering with a hydrant or taking water without the use of a meter. Please report this to our office immediately.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

Table of Detected Contaminants Wilton Water & Sewer Authority PWS ID#NY4500186							
Contaminant	Violation Yes/No	Date of Sample	Level Detected	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely source of Contamination
Inorganic Contaminants							
Arsenic (O'Brien)	N	8/15/22	1.0	µg/l	N/A	MCL=10	Erosion of natural deposits
Arsenic (Fairways)		8/5/22	1.0				
Chloride (O'Brien)	N	7/10/23	161	mg/l	N/A	MCL=250	Geology; Naturally occurring; indicative of
Chloride (Mulberry)	N	7/10/23	84.3				road salt contamination.
Chloride (Fairways)		8/5/22	164				
Barium (O'Brien) – TP-02	N	8/15/22	65.2	µg/l	2000	MCL=2000	Erosion of natural deposits
Barium (Mulberry) – TP-01		8/15/22	15.1				
Barium (Fairways)		8/5/22	65.6				
Copper range	N	6/13/23	0.115 ^{1a} 0.0105-0.136	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits;
Lead range		6/13/23	1.6 ^{2a} ND-4.9	µg/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Manganese (O'Brien)	N	7/10/23	24.4	µg/l	N/A	300	Geology; Naturally occurring
Manganese (Fairways)		8/5/22	28.5				
Manganese (Mulberry)		7/10/23	2.6				
Nickel (O'Brien)	N	8/15/22	0.7	µg/l	N/A	N/A	Erosion of natural deposits
Nickel (Mulberry)		8/15/22	0.6				
Nickel (Fairways)		8/5/22	1.9				
Nitrate (as Nitrogen) Fairway	N	8/15/22	1.52	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (as Nitrogen) Mulberry		7/10/23	0.652				
Nitrate (as Nitrogen) O'Brien		7/10/23	1.47				
Odor (Fairway)	N	8/15/22	1	units	N/A	MCL=3	Natural sources
Sodium ³ (O'Brien)	N	7/10/23	84.9	mg/l	N/A	N/A	Naturally Occurring, Road salt
Sodium ³ (Mulberry)		7/10/23	46.1				
Sodium ³ (Fairways)		8/5/22	94.9				
Sulfate (O'Brien)	N	7/10/23	24.1	mg/l	N/A	MCL=250	Naturally Occurring,
Sulfate (Mulberry)		7/10/23	17.9				
Sulfate (Fairways)		8/5/22	23.5				
Zinc (O'Brien)	N	7/10/23	7.1	µg/l	N/A	MCL=5000	Naturally occurring; Mining waste; Corrosion inhibitor
Zinc (Mulberry)		7/10/23	7.5				
Disinfection By-Products							
HAA5 (Haloacetic Acids) Avg Range of values	N	2/6/23 5/8/23 8/7/23 11/14/23	State Police 53.475 ⁷ 18.9-78.8 Town Hall 42.0 ⁷ 24.4-51.6	µg/l	N/A	MCL=60	By-product of drinking water disinfection needed to kill harmful organisms.

TTHM [Trihalomethanes] Avg range of values	N	2/6/23 5/8/23 8/7/2311/ 14/23	State Police 66.93 ⁷ 27.0-77.9- Town Hall 63.2 ⁷ 35.9-80.4		N/A	MCL=80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains organic matter.
Chlorine Residual (average) (range)	N	Daily testing	1.05 0.6-1.31	ppm	N/A	MCL=4	Used in the treatment and disinfection of drinking water
Unregulated Polyfluoroalkyl Substances							
6:2 FTS Mulberry WTP.	N	5/8/23	2.21	ng/l	N/A	MCL=50,000	Released into the environment from widespread use in commercial and industrial applications.
Table of Detected Contaminants City of Saratoga Springs PWS ID# NY4500168							
Inorganic Contaminants							
Barium	N	12/5/23	32	µg/l	N/A	MCL=2000	Erosion of natural deposits
Chloride	N	12/5/23	140	mg/l	100	MCL=250	Geology; Naturally occurring
Color	N	12/5/23	5	units	N/A	MCL=15	Large quantities of organic chemicals, inadequate treatment, high disinfectant demand and the potential for production of excess amounts of disinfectant byproducts such as trihalomethanes, the presence of metals such as copper, iron and manganese; Natural color may be caused by decaying leaves, plants, and soil organic matter.
Fluoride	N	12/5/23	0.77	mg/l	N/A	MCL=2.2	Erosion of natural deposits; Water additive that promotes strong teeth
Nitrate	N	12/5/23	0.62	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Nickel	N	12/5/23	1.9	µg/l	N/A	N/A	Erosion of natural deposits
Odor	N	12/5/23	1	units	N/A	MCL=3	Organic or inorganic pollutants originating from municipal and industrial waste discharges; natural sources.
Sodium ¹	N	12/5/23	81	mg/l	N/A	N/A	Naturally Occurring, Road salt
Sulfate	N	12/5/23	19	mg/l	N/A	MCL=250	Naturally Occurring,
Synthetic Organic Chemicals							
PFOA	N	3/14/23	2.3	ng/l	N/A	MCL=10 ³	Released into the environment from widespread use in commercial and industrial applications
PFOS	N	3/14/23	0.5				
Unregulated Polyfluoroalkyl Substances							
PFHPA	N		0.81	ng/l	N/A	MLC-50,000 ⁴	Released into the environment from widespread use in commercial and industrial applications
PFPEA			2.3				
PFHXS			0.6				
PFHXA			2.4				
PFBA			3.2				
PFBS ⁴			1.9		2000		
Organic Contaminants							
Total Organic Carbon Quarterly Compliance Ratio Range ⁵	N	Monthly 2023	1.0-1.5	N/A	N/A	TT	Organic material both natural and man made
Microbiological Contaminants							
Turbidity (Highest Value) ⁶	N	11/24/23	0.416	NTU	N/A	TT=1.0 NTU	Soil runoff
2023			99%			TT= 95% samples < 0.3	
Notes: 1. Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets. 2. Only PFOA and PFOS have a regulatory limit of 10 ng/l each. 3. All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/L. 4. USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be considered Legally enforceable federal standards and are subject to change as new information becomes available. PFBS (2000 ng/l) and HFPO-DA (10 ng/l) also have Health Advisory Levels 5. Satisfactory removal of total organic carbon with a compliance ration greater than 1. 6. Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of our filtration system. Level detected represents the highest-level detected. Our highest single turbidity measurement for the year 11/24/23 (0.416 NTU). State regulations require that turbidity must always be below 1 NTU. The regulations also require that 95% of the turbidity samples collected have measurements below 0.3 NTU. In 2023 99% of our measurements met that requirement. 7. The average value presented represents the highest LRAA for 2023. The highest LRAA for site LRAA1 for the HAA5 & THM was in the 3 rd quarter of 2023. The highest LRAA for site LRAA2 for the TTHM and HAA5 was in the 3 rd quarter of 2023.							

SARATOGA COUNTY WATER AUTHORITY Public Water Supply Identification Number NY4530222 Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected	Unit Measure ment	MCLG	Regulatory Limit (MCL, TT or AL)	Likely source of Contamination
Inorganic Contaminants							
Barium	N	4/18/23	4	µg/l	2000	MCL=2000	Erosion of natural deposits
Chloride	N	4/18/23	8.1	mg/l	N/A	MCL=250	Geology; Naturally occurring
Manganese	N	4/18/23	2	µg/l	N/A	MCL=300	Geology; Naturally occurring
Nitrate	N	3/8/23	0.11	mg/l	10,000	MCL=10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium ¹	N	4/18/23	7.2	mg/l	N/A	N/A	Naturally occurring; Road Salt, animal waste and water softeners
Unregulated Polyfluoroalkyl Substances							
PFBA	N	6/13/23	1.27	ng/l	N/A	MCL=50,000 ⁵	Released into the environment from widespread use in commercial and industrial applications
Microbiological Contaminants							
Turbidity (Highest Value) ²	N	6/10/23	0.083	NTU	N/A	TT=1.0 NTU	Soil runoff
			100%			TT= 95% samples < 0.3	
Total Organic Carbon (TOC)							
TOC Raw Water (average) Treated water (average)	N	Monthly samples 2023	4.48 1.89	mg/l	N/A	TT ³	Naturally present in the environment
Notes: 1. Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets. 2. Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of our filtration system. Level detected represents the highest-level detected in 2022 for combined filter effluent (0.072 NTU.). State regulations require that entry point turbidity must always be below 1.0 NTU. The regulations also require that 95% of the turbidity samples collected have measurements below 0.3 NTU. Distribution system turbidity is measured 5 days a week. Our highest distribution turbidity was 0.190 NTU. 3. TOC removals from the water treatment process met the specified target values . 4. Only PFOA and PFOS have a regulatory limit of 10 ng/l each. 5. All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/l 6. USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be considered Legally enforceable federal standards and are subject to change as new information becomes available. PFBS (2000 ng/l) and HFPO-DA (10 ng/l) also have Health Advisory Levels.							

Glossary of Terms

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) (ng/l) corresponds to one part of liquid to one trillion parts of liquid

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

90th Percentile Value- The values reported for lead and copper represent the 90th percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead and copper values detected at your water system

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)- The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Locational Running Annual Average (LRAA) - The LRAA is calculated each quarter by taking the average of the four most recent samples collected at each site

N/A- Not applicable

As illustrated in the tables above, WWSA monitoring and testing detected some contaminants; all other contaminants were below the maximum levels permitted by the State, known as the maximum contaminant levels (MCL). Many of the test results were **NON-DETECTABLE**. The type/group (number of contaminants in each group) tested for were as follows: volatile organic compounds (52) + MTBE, synthetic organic compounds (38), asbestos, & odor (Mulberry only) The inorganic

contaminants tested for and non-detectable were: cadmium, chromium mercury, silver, selenium, antimony, beryllium, thallium, and cyanide. Microbiological Contaminants (2) total coliform and *E. coli*.

As illustrated in the tables above, the City of Saratoga Springs monitoring and testing detected some contaminants; all other contaminants were below the maximum levels permitted by the State, known as the maximum contaminant levels (MCL). Many of the test results were **NON-DETECTABLE**. The type/group (number of contaminants in each group) tested for were as follows: volatile organic compounds (52) + MTBE, synthetic organic compounds (38), asbestos,. The inorganic contaminants tested for and non-detectable were, arsenic, cadmium, chromium, mercury, silver, zinc, antimony, nickel thallium, and cyanide. Microbiological Contaminants (2) Total Coliform and *E. coli*. Radiological contaminants (3) gross alpha, radium 226 and radium 228.

Also illustrated in the tables above, the Saratoga County Water Authority monitoring and testing detected some contaminants; all other contaminants were below the maximum levels permitted by the State, known as the maximum contaminant levels (MCL). Many of the test results were **NON-DETECTABLE**. The type/group (number of contaminants in each group) tested for were as follows: volatile organic compounds (52) + MTBE, synthetic organic compounds (38), asbestos, color. The inorganic contaminants tested for and non-detectable were, arsenic, cadmium, chromium, mercury, nickel, silver, zinc, antimony, beryllium, thallium, and cyanide. Microbiological Contaminants (2) Total coliform, *E. coli*. Radiological contaminants (3) gross alpha, radium 226 and radium 228.

Town of Wilton Water & Sewer Authority
PWSID # NY4500186
SWAP Summary

The NYS DOH has completed a source water assessment for these systems, based on available information. Possible and actual threats to the drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells or surface water supplies. The susceptibility rating is an estimate of the potential for contamination of a given source water. It does not mean that the water delivered to consumers is, or will become contaminated. A list of contaminants detected, if any, are listed in the section entitled “Are their contaminants in our drinking water?” The source water assessments provide resource managers with additional information for protecting source waters into the future.

The Fairways and Mulberry assessments have rated our ground water sources as having an elevated susceptibility to microbials and nitrates. These ratings are due primarily to close proximity of the wells to permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) and the residential land use in the assessment area. In addition, the wells draw from fractured bedrock and the overlying soils may not provide adequate protection from potential contamination. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination.

City of Saratoga Springs
PWSID # NY4500168
SWAP Summary

The NYS DOH has completed source water assessments for both the Bog Meadow Brook and Loughberry Lake Watershed systems based on available information. Possible and actual threats to these drinking water sources were evaluated. The State source water assessments include a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the environment. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “Are there contaminants in our drinking water?” for a list of the contaminants that have been detected, if any. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The Loughberry Lake Watershed assessment found an elevated susceptibility to contamination for this source of drinking water. The amount of pasture in the assessment area results in a medium potential for protozoa contamination, and the amount of residential lands in the assessment area results in an elevated potential for microbials contamination. A single non-sanitary wastewater discharge is unlikely to contribute to contamination. There are no noteworthy contamination threats associated with other discrete contaminant sources. Finally, it should be noted that hydrologic characteristics (e.g. basin shape and flushing rates) generally make reservoirs highly sensitive to existing and new sources of phosphorus and microbial contamination.

The Bog Meadow Brook assessment found a moderate susceptibility to contamination for this source of drinking water. The amount of row crops in the assessment area results in a medium susceptibility to pesticides, and there is reason to believe that land cover data may overestimate the percentage of pasture in the assessment area. No permitted discharges are found in the

assessment area. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facility types include: mines. Finally, it should be noted that relatively high flow velocities make river drinking water supplies highly sensitive to existing and new sources of microbial contamination.

The State Health Department will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, and planning and education programs. A copy of the assessments can be obtained by contacting us, as at the number in the report.

Saratoga County Water Authority
PWSID # NY4530222
SWAP Summary

A source water assessment was performed on this water source, using available data, to determine the susceptibility to contamination. It is important to note that this assessment was created using available information and only estimates the potential for source water contamination.

Our drinking water is derived from a surface water source, the Hudson River. Hydrologic characteristics generally make rivers highly sensitive to existing and new sources of nitrate, phosphorus and microbial contamination. Elevated susceptibility ratings do not mean that source water contamination has or will occur for this Public Water System (PWS). This PWS provides treatment and regular monitoring to ensure that the water delivered to consumers meets all applicable standards. Continued vigilance in compliance with water quality protection and pollution prevention programs as well as continued monitoring and enforcement will help to continue to protect our source water quality.

Unregulated Perfluoroalkyl Substances / Regulated			
pfbis	Perfluorobutanesulfonic acid	NA	Hfpo-da
pfhpa	Perfluoroheptanoic acid	pfba	Perfluorobutanoic acid
pfhxs	Perfluorohexane sulfonic acid	6:2 fts	Perfluorooctane sulfonic acid
pfna	Perfluorononanoic acid	4:2 fts	Perfluorohexane sulfonic acid
<i>pfos</i>	<i>Perfluorooctane sulfonic acid</i>	8:2 fts	Perfluorodecane sulfonic acid
<i>pfoa</i>	<i>Perfluorooctanoic acid</i>	pfmpa	Perfluoro
pfda	Perfluorodecanoic acid	pfpea	Perfluoropentanoic acid
pfdoa	Perfluorododecanoic acid	pfmba	Perfluoro-4-methoxybutanoic acid
pfhxa	Perfluorohexanoic acid	pfeesa	Perfluoro(2-ethoxyethane)sulphonic acid
pfuna	Perfluoroundecanoic acid	nfdha	Nonafluoro-3,6-dioxaheptanoic acid
NA	n11cl-pf3ouds	pfpes	Perfluoropentane sulfonic acid
NA	9cl-pf3ons	pfhps	Perfluoroheptane sulfonic acid
NA	Adona		

Notes: The two regulated compounds are in italics and have MCLs of 10 ng/L each.

The remaining 23 compounds are unregulated.

All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/L. or 50,000 ng/L